

A diagram showing a vertical line with a downward-pointing arrowhead, representing a force vector acting downwards.



CUSTOMER: HUGHES TANK COMPANY	
PROJECT: 15K Permatank	
CAPACITY: 15,275 Gallons	WEIGHT: 12,500 Lbs



- A. Design Pressure: Atmospheric.
- B. Design Temperature: Ambient.
- C. Exterior: Min. 100 mils FBG jacketed dual-wall Permatank®.
- D. Seal welded striker plates under all openings.
- E. All fittings to be protected for shipment.

Fabricated per UL 58 specifications single wall construction.

- Air test are no less than 3 PSI and no more than 5 PSI.
- Primary tank to be tested alone. Secondary tank to be pressure tested with primary tank. This shall be accomplished by bleeding air from the primary tank to the secondary tank.

SIGNATURE: _____

DATE: _____

APPROVED:	Bobby Hughes
CHECKED:	Bode Draper
DRAWN:	Roosevelt Caceres